



In Reply Refer To:
MSHA:A&CC:PAR 98146
Record File No. 18-FHA100001

May 21, 2010

Mr. Stan Stripe
KFH Industries
2926 Columbia Highway
Dothan, AL 36303

Dear Mr. Stripe:

The review of your application dated March 29, 2010, for type KFH NF-MSHA V2 (compound J) Fire Hose Liner is complete.

This construction and the information provided meet the requirements Title 30 Code of Federal Regulations (30CFR) Part 18 and the Standard Application Procedures for Acceptance of Flame-Resistant Solid Products Taken into Mines.

The following requirements apply to this acceptance:

1. Acceptance Marking No. "MSHA No. 18-FHA100001" must be permanently marked on the product with letters at least 1/4" high and at intervals not exceeding 3 feet. Other types of permanent markings may be used with prior approval of MSHA.
2. The accepted material thickness range is 0.04" to 0.07".
3. You are obligated, as the manufacturer, to maintain the quality of the product to ensure the requirements of this acceptance are being met.
4. Any change in product composition or in any other factors that may affect this acceptance must not be made without prior authorization from MSHA.
5. We have the right to revoke this acceptance for cause at any time.
6. This acceptance applies to use as an inner liner for fire hose.

An invoice for the cost of processing this action will be forthcoming.

If you have any comments or questions relative to this letter, please refer them to David Creamer at 304-547-2085.

Sincerely,

A handwritten signature in cursive script, appearing to read "Kenneth A. Sproul".

Kenneth A. Sproul
Acting Chief, Approval and Certification Center